

# 2023 Annual Drinking Water Quality Report

(Consumer Confidence Report)

## Elgin MUD # 2

Phone No. (512) 246-1400

*Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:*

Some people may be more vulnerable to contaminants in drinking water, such as Cryptosporidium, than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

### **Public Participation Opportunities**

Please call (512) 246-1400 to confirm meeting dates and times.

The District's water system is operated by Crossroads Utility Services, LLC. If you have any questions concerning water quality or the source of your water, please call (512) 246-1400 or (512) 246-5905.

### **Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements**

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

**WATER SOURCES:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

### ***En Español***

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español favor de llamar al tel. (512) 246-1400 para hablar con una persona bilingüe en español.

## **Where do we get our drinking water?**

Your drinking water is supplied to you through the distribution system as owned by The Elgin Mud 2 (the District). The District purchases all of its water from Aqua Water Supply Corporation, who obtains groundwater from wells located in the following Aquifers: the Simsboro Sand Member of Rockdale Formation, Wilcox Group, Hooper Formation, and Carrizo Sand. TCEQ completed an assessment of our source water and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for our water system are based on this susceptibility and previous sample data. Any detection of these contaminants will be found in this report. For more information on source water assessments and protection efforts at our system, please contact us.

### ***ALL drinking water may contain contaminants.***

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

### **Secondary Constituents**

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concerns. Therefore, secondaries are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

## **About the Following Pages**

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

### **DEFINITIONS**

#### **Maximum Contaminant Level (MCL)**

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

#### **Maximum Contaminant Level Goal (MCLG)**

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

#### **Maximum Residual Disinfectant Level (MRDL)**

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

#### **Maximum Residual Disinfectant Level Goal (MRDLG)**

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

#### **Treatment Technique (TT)**

A required process intended to reduce the level of a contaminant in drinking water.

#### **Action Level (AL)**

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

### **ABBREVIATIONS**

NTU – Nephelometric Turbidity Units

MFL – million fibers per liter (a measure of asbestos)

pCi/L – picocuries per liter (a measure of radioactivity)

ppm – parts per million, or milligrams per liter (mg/L)

ppb – parts per billion, or micrograms per liter (µg/L)

ppt – parts per trillion, or nanograms per liter

ppq – parts per quadrillion, or picograms per liter

## Inorganic Contaminants

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Source of Contaminant
2023	Antimony (ppb)	<1.0	<1.0	<1.0	6	6	Discharge from petroleum refineries, fire retardants, ceramics, electronics, solder.
2023	Arsenic (ppb)	<2.0	<2.0	<2.0	0.01	0	Naturally occurring element in minerals and metals. Poisonous to multicellular life.
2023	Asbestos (MFL)	<0.19	<0.19	<0.19	7	7	Decay of asbestos cement in water mains; erosion of natural deposits.
2023	Barium (ppm)	0.115	0.115	0.115	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
2023	Fluoride (ppm)	0.21	0.21	0.21	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2023	Selenium (ppb)	<3.0	<3.0	<3.0	50	50	Selenium is a metal found in natural deposits such as ores containing other elements.
2023	Nitrate* (ppm)	<0.05	<0.05	<0.05	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2023	Nitrite* (ppm)	<0.05	<0.05	<0.05	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2023	Nitrate Nitrite	<0.05	<0.05	<0.05	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2023	Gross alpha emitters (pCi/L)	<3.0	<3.0	<3.0	15	0	Decay of natural and man-made deposits.
2023	Gross beta particles (pCi/L)	<4.0	<4.0	<4.0	50	0	Decay of natural and man-made deposits.
2023	Combined Radium-226/228 (pCi/L)	<1.0	<1.0	<1.0	5	0	Decay of natural and man-made deposits.

\*Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. If you are caring for an infant you should ask advice from your health care provider.

## Organic Contaminants TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

### Volatile Organic Contaminants

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Source of Contaminant
2023	Benzene (ppb)	<0.5	<0.5	<0.5	5.0	5.0	Petrochemical runoff
2023	Vinyl Chloride (ppb)	<0.5	<0.5	<0.5	2	2	Leaching from PVC piping; Discharge of plastic factories

### Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Source of Disinfectant
2023	Chlorine (ppm)	0.98	0.53	1.14	4.0	<4.0	Disinfectant used to control microbes

### Lead and Copper

Year	Contaminant	The 90 <sup>th</sup> Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2023	Lead	N/T	Yet	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits.
2023	Copper	N/T	Yet	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

### Required Additional Health Information for Lead

*"If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality*

drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”

### Disinfection Byproducts

Year	Contaminant	LR Annual Average	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2023	Total Haloacetic Acids	N/T	Yet		60	ppb	Byproduct of drinking water disinfection.
2023	Total Trihalomethanes	N/T	Yet		80	ppb	Byproduct of drinking water disinfection.

### Unregulated Initial Distribution System Evaluation for Disinfection Byproducts WAIVED OR NOT YET SAMPLED

#### Unregulated Contaminants

Bromoform, chloroform, bromodichloromethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.							
Year	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant	
2023	Chloroform	N/T	Yet		ppb	Byproduct of drinking water disinfection.	
2023	Bromoform	N/T	Yet		ppb	Byproduct of drinking water disinfection.	
2023	Bromodichloromethane	N/T	Yet		ppb	Byproduct of drinking water disinfection.	
2023	Dibromochloromethane	N/T	Yet		ppb	Byproduct of drinking water disinfection.	

#### Secondary and Other Constituents Not Regulated (No associated adverse health effects)

Year	Contaminant	Average Level	Min. Level	Max. Level	Limit	Source of Contaminant
2023	Aluminum (ppm)	<0.02	<0.02	<0.02	0.05	Abundant naturally occurring element.
2023	Bicarbonate (mg/L)	216	216	216	NA	Corrosion of household plumbing systems; erosion of natural deposits; leaching from preservatives
2023	Calcium (mg/L)	80.1	80.1	80.1	NA	Abundant naturally occurring element.
2023	Chloride (mg/L)	47	47	47	300	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
2023	Iron (mg/L)	0.064	0.064	0.064	NA	Abundant naturally occurring element.
2023	Magnesium (mg/L)	10.2	10.2	10.2	NA	Abundant naturally occurring element.
2023	Manganese (mg/L)	0.005	0.005	0.005	NA	Abundant naturally occurring element.
2023	Nickel (mg/L)	0.0014	0.0014	0.0014	NA	Erosion of natural deposits.
2023	pH (mg/L)	7.1	7.1	7.1	7	Measure of corrosivity of water.
2023	Sodium (mg/L)	27.6	27.6	27.6	NA	Erosion of natural deposits; byproduct of oil field activity.
2023	Sulfate (mg/L)	62	62	62	300	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
2023	Total Alkalinity as CaCO3 (mg/L)	177	177	177	NA	Naturally occurring soluble mineral salts.
2023	Total Dissolved Solids ( mg/L)	367	367	367	1000	Total dissolved mineral constituents in water.
2023	Total Hardness as CaCO3 (mg/L)	242	242	242	NA	Naturally occurring calcium.

2023 **Total Coliform** REPORTED MONTHLY TESTS FOUND NO TOTAL COLIFORM BACTERIA  
 2023 **Fecal Coliform** REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA

PWS #0110066

N/T Not Tested for yet.

