

2023 Annual Drinking Water Quality Report

(Consumer Confidence Report)

Lazy 9 M.U.D. #1A

Phone No. (512) 246-1400

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:

Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

Some people may be more vulnerable to contaminants in drinking water, such as Cryptosporidium, than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

Public Participation Opportunities

Please call (512) 246-1400 to confirm meeting date and time. The Boards of Directors for this Districts meet on the third Wednesday of each month at 11:30 a.m. at Allen Boone Humphrey and Robinson, LLP, 919 Congress Ave Suite 1500, Austin, Texas, 78701.

The District's water system is operated by Crossroads Utility Services, LLC. If you have any questions concerning water quality or the source of your water, please call (512) 246-1400.

En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español favor de llamar al tel. (512) 246-1400 para hablar con una persona bilingüe en español.

Where do we get our drinking water?

Our drinking water is supplied to you through the distribution system as owned by Lazy 9 M.U.D. #1A (the District). The District purchases water from the West Travis County Public Utility Agency, who obtains surface water from Lake Austin. A Source Water Susceptibility Assessment for your drinking water source is currently being updated by the TCEQ. The report will describe the susceptibility and types of constituents that may come into contact with our drinking water source based on human activities and natural conditions. The information contained in the assessment will allow us and/or the system from which we receive water to focus on source water protection strategies. For more information on source water assessments and protection efforts at our system, please contact us.

ALL drinking water may contain contaminants.

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concerns. Therefore, secondary's are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

About the Following Pages

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

DEFINITIONS

Maximum Contaminant Level (MCL)

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ABBREVIATIONS

NTU – Nephelometric Turbidity Units

MFL – million fibers per liter (a measure of asbestos)

pCi/L – picocuries per liter (a measure of radioactivity)

ppm – parts per million, or milligrams per liter (mg/L)

ppb – parts per billion, or micrograms per liter (µg/L)

ppt – parts per trillion, or nanograms per liter

ppq – parts per quadrillion, or picograms per liter

Inorganic Contaminants

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Source of Contaminant
2017	Asbestos (MFL)	<0.197	<0.197	<0.197	7	7	Decay of asbestos cement in water mains; erosion of natural deposits.
2023	Barium (ppm)	0.065	0.065	0.065	2	2	Discharge of drilling wastes; discharge from metal refineries,; erosion of natural deposits.
2023	Cyanide (ppb)	0.14	0.14	0.14	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
2023	Fluoride (ppm)	0.23	0.23	0.23	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
2022	Nickel (ppm)	0.0058	0.0058	0.0058	0.1	0.1	Abundant naturally occurring element.
2023	Nitrate* (ppm)	0.13	0.12	0.14	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2021	Nitrite (ppm)	<0.05	<0.05	<0.05	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
2021	Nitrate-Nitrite* (ppm)	0.18	0.18	0.18	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

*Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. If you are caring for an infant you should ask advice from your health care provider.

Organic Contaminants

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Source of Contaminant
2022	DI (2-Ethylhexyl Phthalate (ppb)	0.6	0.6	0.6	6.0	0	Discharge from rubber and chemical factories.
2022	Simazene (ppb)	<0.07	<0.07	<0.07	4	4	Herbicide runoff.

Volatile Organic Contaminants

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2022	Vinyl Chloride	<0.5	<0.5	<0.5	2	ppb	Leaching from PVC piping; Discharge of plastic factories

Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Source of Disinfectant
2023	Chloramines (ppm)	1.63	0.89	2.5	4.0	<4.0	Disinfectant used to control microbes

Disinfection Byproducts

Year	Contaminant	LRAnnual Average	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2023	Total Haloacetic Acids	11.1	11.1	11.1	60	ppb	Byproduct of drinking water disinfection.
2023	Total Trihalomethanes	37.2	37.2	37.2	80	ppb	Byproduct of drinking water disinfection.

Unregulated Contaminants

Bromoform, chloroform, bromodichloromethane, and dibromochloromethane are disinfection byproducts. There is no maximum contaminant level for these chemicals at the entry point to distribution.							
Year	Contaminant	Average Level	Minimum Level	Maximum Level		Unit of Measure	Source of Contaminant
2023	Chloroform	4.9	4.9	4.9		ppb	Byproduct of drinking water disinfection.
2023	Bromoform	6.3	6.3	6.3		ppb	Byproduct of drinking water disinfection.
2023	Bromodichloromethane	11.3	11.3	11.3		ppb	Byproduct of drinking water disinfection.
2023	Dibromochloromethane	14.7	14.7	14.7		ppb	Byproduct of drinking water disinfection.

Lead and Copper

Year	Contaminant	The 90 th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2023	Lead	0.0025	0	15	ppm	Corrosion of household plumbing systems; erosion of natural deposits.
2023	Copper	0.164	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.

Required Additional Health Information for Lead

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of material used plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.”

Turbidity

Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Source of Contaminant
2023	Turbidity (NTU)	0.25	100%	0.3	Soil runoff.

2023 **Total Coliform** REPORTED MONTHLY TEST FOUND NO TOTAL COLIFORM BACTERIA

2023 **Fecal Coliform** REPORTED MONTHLY TEST FOUND NO FECAL COLIFORM BACTERIA

Secondary and Other Constituents Not Regulated (No associated adverse health effects)

Year	Contaminant	Average Level	Minimum Level	Maximum Level	Limit	Source of Contaminant
2022	Aluminum (ppm)	<0.02	<0.02	<0.02	0.2	Abundant naturally occurring element.
2022	Bicarbonate (ppm)	187	187	187	NA	Corrosion of carbonate rocks such as limestone.
2022	Calcium (ppm)	37.7	37.7	37.7	NA	Abundant naturally occurring element.
2022	Chloride (ppm)	43	43	43	300	Abundant naturally occurring element; used in water purification; byproduct of oil field activity.
2022	Magnesium (ppm)	21.9	21.9	21.9	NA	Abundant naturally occurring element.
2022	Manganese (ppm)	0.0013	0.0013	0.0013	0.05	Abundant naturally occurring element.
2021	pH (units)	7.67	7.6	7.9	7	Measure of corrosivity of water.
2022	Sodium (ppm)	24.4	24.4	24.4	NA	Erosion of natural deposits; byproduct of oil field activity.
2022	Sulfate (ppm)	26	26	26	300	Naturally occurring; common industrial byproduct; byproduct of oil field activity.
2022	Total Alkalinity as CaCO ₃ (ppm)	156.53	151	162	NA	Naturally occurring soluble mineral salts.
2022	Total Dissolved Solids (ppm)	301	301	301	1000	Total dissolved mineral constituents in water.
2022	Total Hardness as CaCO ₃ (ppm)	184	184	184	NA	Naturally occurring calcium.
2022	Zinc (ppm)	0.0105	0.0105	0.0105	5	Moderately abundant naturally occurring element; used in the metal industry.

Violations Table

P.W.S. #2270374

